



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

James Eberts
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

8/10/2021

Phone: (856) 205-1077

Fax: (856) 205-0413

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/27/2021. The results are tabulated on the attached data pages for the following client designated project:

Project ID: NJ DOE
Millville Public Charter School

The reference number for these samples is EMSL Order #012108359. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012108359
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 7/27/2021 09:00 AM

Project: Millville Public Charter School

Analytical Results

Client Sample Description MPCS-WC-02-HALL (R)
Near Stairs Right
Collected: 7/24/2021 8:40:00 AM
Lab ID: 012108359-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.07	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:11

Client Sample Description MPCS-WC-02-HALL (L)
Near Stairs Left
Collected: 7/24/2021 8:40:00 AM
Lab ID: 012108359-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:12

Client Sample Description MPCS-SO-01-BAYOFF
Bayda Off Kitchen
Collected: 7/24/2021 8:44:00 AM
Lab ID: 012108359-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	26.1	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:13

Client Sample Description MPCS-SO-01-BAYOFF
Bayda Off Kitchen
Collected: 7/24/2021 8:45:00 AM
Lab ID: 012108359-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.9	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:15

Client Sample Description MPCS-SO-02-KIT1
Kitchen Bay Sink
Collected: 7/24/2021 8:47:00 AM
Lab ID: 012108359-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.41	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:16

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012108359
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 7/27/2021 09:00 AM

Project: Millville Public Charter School

Analytical Results

Client Sample Description MPCS-SO-02-KIT2
 Small Kitch. Sink
Collected: 7/24/2021 8:47:00 AM
Lab ID: 012108359-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.64	1.00 ppb	8/9/2021 VD	8/10/2021 00:18 VD

Client Sample Description MPCS-SO-01-DOWNOFF
 Downstairs Off Suite
Collected: 7/24/2021 8:52:00 AM
Lab ID: 012108359-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	31.2	1.00 ppb	8/3/2021 KG	8/4/2021 21:49 JW

Client Sample Description MPCS-SO-01-DOWNOFFF
 Downstairs Off Suite
Collected: 7/24/2021 8:53:00 AM
Lab ID: 012108359-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.18	1.00 ppb	8/9/2021 VD	8/10/2021 00:24 VD

Client Sample Description MPCS-SO-01-ADMOFF
 Admin Off Kitchen
Collected: 7/24/2021 8:56:00 AM
Lab ID: 012108359-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	32.7	1.00 ppb	8/9/2021 VD	8/10/2021 00:29 VD

Client Sample Description MPCS-SO-01-ADMOFFF
 Admin Off Kitchen
Collected: 7/24/2021 8:57:00 AM
Lab ID: 012108359-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.96	1.00 ppb	8/9/2021 VD	8/10/2021 00:33 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012108359
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 7/27/2021 09:00 AM

Project: Millville Public Charter School

Analytical Results

Client Sample Description MPCS-SO-01-ORTHO
Ortho Break Room
Collected: 7/24/2021 9:03:00 AM
Lab ID: 012108359-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	17.1	1.00 ppb	8/3/2021 KG	8/4/2021 21:52 JW
-------	------	------	----------	-------------	-------------------

Client Sample Description MPCS-SO-01-ORTHOF
Ortho Break Room
Collected: 7/24/2021 9:04:00 AM
Lab ID: 012108359-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 00:34 VD
-------	------	----	----------	-------------	--------------------

Client Sample Description MPCS-CS-01-1A(2)
Room 1A Right
Collected: 7/24/2021 9:08:00 AM
Lab ID: 012108359-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 00:35 VD
-------	------	----	----------	-------------	--------------------

Client Sample Description MPCS-CS-01-1A(1)
Room 1A Left
Collected: 7/24/2021 9:08:00 AM
Lab ID: 012108359-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 00:41 VD
-------	------	----	----------	-------------	--------------------

Client Sample Description MPCS-WC-01-HALL3
Right Hall by Main Off
Collected: 7/24/2021 9:10:00 AM
Lab ID: 012108359-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 00:43 VD
-------	------	----	----------	-------------	--------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012108359
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 7/27/2021 09:00 AM

Project: Millville Public Charter School

Analytical Results

Client Sample Description MPCS-WC-01-HALL2
 Left Hall by Main Off **Collected:** 7/24/2021 9:11:00 AM **Lab ID:** 012108359-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:44

Client Sample Description MPCS-BF-01-HALL2
 Left Hall by Main Off **Collected:** 7/24/2021 9:11:00 AM **Lab ID:** 012108359-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.41	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:46

Client Sample Description MPCS-NS-01-NUR
 Nurse's Office **Collected:** 7/24/2021 9:15:00 AM **Lab ID:** 012108359-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.55	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:47

Client Sample Description MPCS-WO-02-RMLEFT
 Upstairs Room near Bathroom Left **Collected:** 7/24/2021 9:20:00 AM **Lab ID:** 012108359-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:55

Client Sample Description MPCS-WC-02-HALL3
 Right Hall by 3C **Collected:** 7/24/2021 9:30:00 AM **Lab ID:** 012108359-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012108359
 CustomerID: EPIC62
 CustomerPO: NJ-DOE
 ProjectID: NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 7/27/2021 09:00 AM

Project: Millville Public Charter School

Analytical Results

Client Sample Description MPCS-WC-02-HALL2
 Left Hall by 3C **Collected:** 7/24/2021 9:30:00 AM **Lab ID:** 012108359-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 00:59

Client Sample Description MPCS-BF-02-HALL2
 Right Hall by 7A **Collected:** 7/24/2021 9:31:00 AM **Lab ID:** 012108359-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 01:00

Client Sample Description MPCS-WC-01-HALL5
 Left Hall by 7A **Collected:** 7/24/2021 9:35:00 AM **Lab ID:** 012108359-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 01:01

Client Sample Description MPCS-WC-01-HALL4
 Left Hall by 7A **Collected:** 7/24/2021 9:36:00 AM **Lab ID:** 012108359-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 01:03

Client Sample Description MPCS-BF01-HALL4
 Art Room Storage **Collected:** 7/24/2021 9:37:00 AM **Lab ID:** 012108359-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.66	1.00 ppb	8/9/2021 VD	8/10/2021 VD 01:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012108359
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 7/27/2021 09:00 AM

Project: **Millville Public Charter School**

Analytical Results

Client Sample Description MPC5-SO-ARTSTOR
 Art Room Storage **Collected:** 7/24/2021 9:39:00 AM **Lab ID:** 012108359-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.2	1.00 ppb	8/9/2021 VD	8/10/2021 VD 14:02

Client Sample Description Field Blank **Collected:** 7/24/2021 9:41:00 AM **Lab ID:** 012108359-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	8/9/2021 VD	8/10/2021 VD 14:06

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results